

**CONTRACT CHANGE ORDER**

Change Requested by: Contractor

CCO: 35	Suppl. No. 0	Contract No. 04 - 0120F4	Road SF-80-13.2/13.9	FED. AID LOC.:
---------	--------------	--------------------------	----------------------	----------------

**To: AMERICAN BRIDGE/FLUOR ENTERPRISES INC A JOINT VENT**

You are directed to make the following changes from the plans and specifications or do the following described work not included in the plans and specifications for this contract. **NOTE: This change order is not effective until approved by the Engineer.**

Description of work to be done, estimate of quantities and prices to be paid. (Segregate between additional work at contract price, agreed price and force account.) Unless otherwise stated, rates for rental of equipment cover only such time as equipment is actually used and no allowance will be made for idle time. This last percentage shown is the net accumulated increase or decrease from the original quantity in the Engineer's Estimate.

Allow the Contractor to use the Quadrel iQdrum "QDRUM" calorimeter to measure Adiabatic Heat Signature in lieu of the "Heat of Hydration" method for determining the adiabatic temperature rise of concrete as required in Section 10-1.45, "CONCRETE STRUCTURES", subsection "Heat of Hydration" of the Contract Special Provisions.

All work shall be in accordance with the Contract Special Provisions and applicable ASTM Specifications.

This is a Contractor requested change order.

The Contractor agrees to perform this work at no additional cost to the Department.

Estimated Cost: Increase ☐ Decrease ☐ \$0.00

By reason of this order the time of completion will be adjusted as follows: 0 days

Submitted by		
Signature <i>Gary Pursell</i>	Resident Engineer Gary Pursell, P.E., Sup. T.E.	Date <i>3/30/07</i>
Approval Recommended by		
Signature <i>Richard Morrow</i>	Supervising Bridge Engineer Richard Morrow, P.E., Sup. BE	Date <i>3/30/07</i>
Engineer Approval by		
Signature <i>Gary Pursell</i>	Supervising Transportation Engineer Gary Pursell, P.E., Sup. TE	Date <i>4/16/07</i>

We the undersigned contractor, have given careful consideration to the change proposed and agree, if this proposal is approved, that we will provide all equipment, furnish the materials, except as may otherwise be noted above, and perform all services necessary for the work above specified, and will accept as full payment therefor the prices shown above.

**NOTE:** If you, the contractor, do not sign acceptance of this order, your attention is directed to the requirements of the specifications as to proceeding with the ordered work and filing a written protest within the time therein specified.

Contractor Acceptance by		
Signature <i>Michael D. Flowers</i>	(Print name and title) <i>Michael D. Flowers</i> <i>Project Director</i>	Date <i>4-11-07</i>